IEC 62561-8

Edition 1.0 2026-06

INTERNATIONAL STANDARD

Lightning protection system components (LPSC) -
Part 8: Requirements for components for electrically insulated LPS

ICS 29.020; 91.120.40

ISBN 978-2-8327-1299-3

IEC 62561-8:2026-06(en)

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 8
4 Insulating stand-off 10
4.1 Classification 10
4.1.1 General 10
4.1.2 According to conductor clamping arrangement 10
4.1.3 According to mounting 10
4.2 Requirements 10
4.2.1 General 10
4.2.2 Construction 10
4.2.3 Mechanical requirements 11
4.2.4 Electrical requirements 12
4.2.5 Documentation and installation instructions 13
4.2.6 Marking 13
4.3 Tests 14
4.3.1 General test conditions 14
4.3.2 General test setup 16
4.3.3 Documentation 17
4.3.4 Marking test 17
4.3.5 Environmental influence tests 17
4.3.6 Mechanical tests 18
4.3.7 Electrical test 22
4.4 Electromagnetic compatibility (EMC) 24
4.5 Structure and content of the test report 25
4.5.1 General 25
4.5.2 Report identification 25
4.5.3 Specimen description 25
4.5.4 Characterization and condition of the test specimen or test assembly 26
5 Insulating down-conductor 27
5.1 Classification 27
5.2 Lightning current carrying capability 27
5.3 Preferred values of equivalent separation distance (s_e) 27
5.4 Requirements 27
5.4.1 General 27
5.4.2 Environmental requirements 28
5.4.3 Mechanical requirements 28
5.4.4 Electrical requirements 28
5.4.5 Documentation 29
5.4.6 Marking 29
5.5 Tests 30
5.5.1 General test conditions 30
5.5.2 General test setup 31
5.5.3 Documentation 31

5.5.4 Marking test 31
5.5.5 Environmental influence tests 32
5.5.6 Mechanical tests 33
5.5.7 Electrical tests 33
5.6 Electromagnetic compatibility (EMC) 38
5.7 Structure and content of the test report 38
5.7.1 General 38
5.7.2 Report identification 39
5.7.3 Specimen description 39
5.7.4 Characterization and condition of the test specimen or test assembly 39
5.7.5 Insulating down-conductor 39
5.7.6 Standards and references 39
5.7.7 Test procedure 40
5.7.8 Testing equipment description 40
5.7.9 Measuring instruments description 40
5.7.10 Results and parameters recorded 40
Annex A (normative) Environmental test – Corrosion resistance 41
A.1 General 41
A.2 Salt mist test 41
A.3 Humid sulphurous atmosphere test 41
A.4 Ammonia atmosphere test 41
Annex B (normative) Environmental test – Resistance to ultraviolet light 42
B.1 General 42
B.2 Test 42
B.3 First alternative test to Clause B.2 42
B.4 Second alternative test to Clause B.2 42
Annex C (normative) Flow chart of tests for insulating stand-offs 43
Annex D (normative) Flow chart of tests for insulating down-conductors 44
Annex E (informative) High voltage impulse test to determine the actual correction factor k_X for insulating stand-offs 45
E.1 Specimen preparation 45
E.2 Test setup 45
E.3 Test procedure 45
Annex F (informative) Installation arrangement test to determine the influence of supporting structures on the separation distance 47
F.1 General 47
F.2 Specimen preparation for the high voltage installation arrangement test 47
F.3 Test procedure 48
Annex G (normative) Alternate test arrangement for high voltage impulse test 49
Annex H (normative) Applicability of previous tests 52
Bibliography 53

Figure 1 – Typical insulating stand-off with a metallic fastener 11
Figure 2 – Typical insulating stand-off with a non-metallic fastener 12
Figure 3 – Typical insulating stand-off with a metallic fastener prepared for testing 14
Figure 4 – Typical insulating stand-off with a non-metallic fastener prepared for testing 15
Figure 5 – Basic arrangement for bending test 18

Figure 6 – Pendulum hammer test apparatus 19
Figure 7 – Two alternative basic arrangements for pull out test on rigidly fixed insulating stand-off 21
Figure 8 – Two alternative basic arrangements for pull out test on free standing insulating stand-off 22
Figure 9 – Typical test arrangement for the high voltage impulse test of an insulating stand-off 23
Figure 10 – Specimen preparation for UV light test 32
Figure 11 – Basic arrangement for the lightning current carrying capability test 34
Figure 12 – Test arrangements for the high voltage impulse test of the insulating down-conductor 36
Figure 13 – Test arrangements for insulting down conductors 37
Figure C.1 – Tests for insulating stand-offs 43
Figure D.1 – Tests for insulating down-conductors 44
Figure F.1 – Example for installation arrangement test – Specimen under test 47
Figure F.2 – Alternate example for installation arrangement test – Specimen under test 48
Figure G.1 – Typical test arrangement for the high voltage impulse test of an insulating stand-off – Alternate test arrangement to Figure 9 49
Figure G.2 – General description of the test setup for the high voltage impulse test of the insulating down-conductor – Alternate test set-up to Figure 12 a) 50
Figure G.3 – Alternate test arrangement for the high voltage impulse test of the insulating down conductor – alternate test set-up to Figure 12 b) 50
Figure G.4 – General description rod tip and rod – Plane arrangement geometry 51

Table 1 – Type test requirements for an insulating stand-off 16
Table 2 – Lightning impulse current (I_{imp}) parameters 27
Table 3 – Type test requirements for an insulating down-conductor 31
Table H.1 – Differences in the requirements for electrically insulated LPS complying with IEC TS 62561-8:2018 52

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Lightning protection system components (LPSC) - Part 8: Requirements for components for electrically insulated LPS

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62561-8 has been prepared by IEC technical committee 81: Lightning protection. It is an International Standard.

This first edition cancels and replaces IEC TS 62561-8 published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TC 62561-8:2018:

a) title and scope of the standard has been adjusted;
b) the document has been updated in line with IEC 60068-2-52:2017 on salt mist treatment;
c) the document has been updated in line with ISO 22479:2019 on humid sulphureous atmosphere treatment;
d) two different possible example configurations for pull out tests have been introduced;
e) additional information on pollution has been included;

f) an alternate test arrangement for high voltage impulse test has been included;

g) a new normative Annex H for applicability of previous tests has been introduced;

h) pass criteria for high voltage impulse testing updated;

i) explanation on high voltage impulse testing with negative polarity has been added.

The text of this International Standard is based on the following documents:

Draft	Report on voting
81/806/FDIS	81/808/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the 62561 series, published under the general title *Lightning protection system components (LPSC)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,

– withdrawn, or

– revised.

INTRODUCTION

This part of IEC 62561 deals with the requirements and tests for lightning protection system components (LPSC), specifically components for electrically insulated LPS, used for the installation of a lightning protection system (LPS) designed and implemented according to the IEC 62305 series [1][1].

[1] Numbers in square brackets refer to the Bibliography.

1 Scope

This document specifies the requirements and tests for components used for electrically insulated LPS. These components, which can reduce the separation distance, are as follows:

– insulating stand-offs, used in conjunction with an air-termination system and down-conductors with the aim of maintaining the proper separation distance;

– insulating down-conductors, including their specific fasteners.

Testing of insulating stand-offs and insulating down-conductor components for an explosive atmosphere is not covered by this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-2:2025, *High-voltage test techniques - Part 2: Measuring systems*

IEC 60068-2-52:2017, *Environmental testing - Part 2-52: Tests - Test Kb: Salt mist, cyclic (sodium chloride solution)*

IEC 60068-2-75:2014, *Environmental testing - Part 2-75: Tests - Test Eh: Hammer tests*

IEC 61083-1, *Instruments and software used for measurements in high-voltage and high-current tests - Part 1: Requirements for instruments for impulse tests*

IEC 61083-2, *Instruments and software used for measurement in high-voltage and high-current tests - Part 2: Requirements for software for tests with impulse voltages and currents*

IEC 62305-3, *Protection against lightning - Part 3: Physical damage to structures and life hazard*

IEC 62561-1:2023, *Lightning protection system components (LPSC) - Part 1: Requirements for connection components*

IEC 62561-2:2025, *Lightning protection system components (LPSC) - Part 2: Requirements for conductors and earth electrodes*

IEC 62561-4, *Lightning protection system components (LPSC) - Part 4: Requirements for conductor fasteners*

ISO 4892-2, *Plastics - Methods of exposure to laboratory light sources - Part 2: Xenon-arc lamps*

ISO 4892-3:2024, *Plastics - Methods of exposure to laboratory light sources - Part 3: Fluorescent UV lamps*

ISO 4892-4, *Plastics - Methods of exposure to laboratory light sources - Part 4: Open-flame carbon-arc lamps*

ISO 6957:1988, *Copper alloys - Ammonia test for stress corrosion resistance*

ISO 22479:2019, *Corrosion of metals and alloys - Sulfur dioxide test in a humid atmosphere (fixed gas method)*

Bibliography

[1] IEC 62305 (all parts), *Protection against lightning*

[2] R. Brocke, O. Beierl: "*Probability of Insulation Failures in Isolated LPS according to the used Insulation Technologies*", Proceedings of the XI SIPDA, Fortaleza, Brazil, Nov. 2011

[3] R. Brocke, O. Beierl: "*Influence of humidity and pollution on the dielectric strength of components used in Isolated LPS*", 32th International Conference on Lightning Protection (ICLP), Shanghai, China, Oct. 2014

[4] W. Zischank, J. Wiesinger, P. Hasse: "*Insulators for Isolated or Partly Isolated Lightning Protection Systems to Verify Safety Distances*" Proceedings of the 23. ICLP, Florenz 1996, pp. 513-518

[5] S. Grzybowski, J. Kappenman, W. A. Radasky: "*Electrical Strength of Distribution Insulators under steep front, short duration pulse*", 17th International Zurich Symposium on Electromagnetic Compatibility, 2006

[6] IEC 62305-1:2024, *Protection against lightning - Part 1: General principles*

[7] IEC TS 62561-8:2018, *Lightning protection components (LPSC) - Part 8: Requirements for components for isolated LPS*

[8] IEC 62305-2:2024, *Protection against lightning - Part 2: Risk management*

[9] IEC 62305-4:2024, *Protection against lightning - Part 4: Electrical and electronic systems within structures*

[10] IEC 60332 (all parts), *Tests on electric cables under fire conditions*

[11] IEC 61034 (all parts), *Measurement of smoke density of cables burning under defined conditions*

_____