

# TECHNICAL SPECIFICATION

---

**High-voltage direct current (HVDC) systems - Guidance to the specification and design evaluation of AC filters -  
Part 2: Harmonic performance aspects**

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Telephone interference.....	7
4.1 Overview of telephone interference issues .....	7
4.2 Determining the necessity for telephone interference limits .....	9
4.3 Defining appropriate telephone interference limits.....	10
4.3.1 General .....	10
4.3.2 Mechanisms of interference.....	11
4.3.3 Noise performance coordination levels .....	12
5 Current-based interference criteria .....	14
5.1 Overview .....	14
5.2 Derivation of parameters.....	14
5.3 Illustrative values of current-based limits .....	17
5.4 Determination of IT limits for a specific project.....	19
5.4.1 General .....	19
5.4.2 Identification of the decisive transmission lines.....	19
5.4.3 Inductive coordination study .....	23
5.4.4 Pre-existing harmonics and future growth .....	23
5.5 Recommendations for technical specifications .....	25
5.6 Consequences of harmonic current limit for filter design .....	27
5.7 Telephone infrastructure mitigation options.....	27
5.8 Experience and examples .....	28
5.8.1 General .....	28
5.8.2 Review of design requirements.....	29
5.8.3 Measured current levels of schemes in service.....	29
5.8.4 Example of actual telephone interference problems .....	31
5.9 Conclusions .....	32
6 Field measurements and verification.....	33
6.1 Overview .....	33
6.2 Equipment and subsystem tests.....	33
6.2.1 General .....	33
6.2.2 Fundamental frequency impedance and unbalance measurement.....	33
6.2.3 Frequency response curve.....	34
6.3 System tests .....	34
6.4 Measuring equipment.....	34
6.4.1 Overview .....	34
6.4.2 AC filter energization .....	37
6.4.3 Verification of the reactive power controller .....	37
6.4.4 Verification of the specified reactive power interchange.....	37
6.4.5 Verification of the harmonic performance.....	37
6.4.6 Verification of audible noise.....	41
6.5 In-service measurements .....	41
6.5.1 General .....	41

6.5.2	Measurement parameters .....	41
6.5.3	Categories of measurements .....	41
Annex A	(informative) Voltage and current distortion – Telephone interference .....	43
A.1	Voltage distortion limits for HV and EHV networks .....	43
A.1.1	General .....	43
A.1.2	Recommended limits for HV or EHV networks.....	44
A.2	Harmonic current in generators .....	46
A.3	Causes of telephone interference.....	46
A.4	Definition of telephone interference parameters .....	48
A.5	Discussion .....	52
A.6	Coupling mechanism from power-line current to telephone disturbance voltage.....	53
Annex B	(informative) Example of induced noise calculation with Dubanton equations.....	54
B.1	General.....	54
B.2	Residual IT .....	54
B.3	Balanced IT .....	55
Annex C	(informative) Illustration of the benefit of including a TIF requirement in the technical specification.....	56
Annex D	(informative) Specification of IT limits dependent on network impedance .....	58
Annex E	(informative) The impact of AC network harmonic impedance and voltage level on the filter design necessary to fulfil an IT criterion .....	62
E.1	General.....	62
E.2	Assumptions and pre-conditions .....	63
E.3	Harmonic impedance of AC network .....	65
E.4	Filter design.....	68
E.5	Explanation of the difference in impact of relative and absolute performance criteria on required filter Mvar .....	69
Annex F	(informative) List of typical HVDC projects .....	71
Bibliography	.....	73
Figure 1	– Conversion factor from positive sequence current at the sending end to positive sequence current at the receiving end, and input impedance of a 230 kV line, 124 km long, 1 000 $\Omega$ -m.....	21
Figure 2	– Conversion factor from positive sequence current to residual current, and input impedance of a 230 kV line, 124 km long, 1 000 $\Omega$ -m .....	22
Figure 3	– Simple circuit for calculation of harmonic performance taking into account pre-existing harmonics.....	24
Figure 4	– Simplified diagram of system in Table 6 .....	30
Figure 5	– Simplified diagram of system in Table 7 .....	31
Figure 6	– Locations for voltage measurements for power quality assessment .....	36
Figure 7	– Converter variables for harmonic performance tests.....	38
Figure 8	– Example of measurements made during a ramp of the converters .....	40
Figure A.1	– Contributions of harmonic voltages at different voltage levels in a simple network.....	43
Figure A.2	– C-message and psophometric weighting factors .....	47
Figure A.3	– Flow-chart describing the basic telephone interference mechanism .....	53
Figure D.1	– Simplification of the detailed network used for telephone interference simulation .....	58

Figure D.2 – Induced voltage in telephone circuit vs. network impedance, for unitary current injected .....	59
Figure D.3 – IT limits as defined for different network impedances.....	60
Figure E.1 – Converter harmonics un-weighted (A) and IT weighted (kA) on 240 kV base .....	64
Figure E.2 – Converter Mvar absorption versus load.....	65
Figure E.3 – Impedance sector diagram and RL-equivalent circuit .....	66
Figure E.4 – Simplified converter/system topology .....	66
Figure E.5 – Simplified circuit including overhead transmission line .....	67
Table 1 – Performance thresholds for metallic noise .....	13
Table 2 – Performance thresholds for longitudinal noise .....	13
Table 3 – Performance thresholds for balance .....	13
Table 4 – Illustrative maximum telephone line length to achieve the North American recommended longitudinal ng level, as a function of balanced IT level, earth resistivity and separation distance .....	17
Table 5 – Illustrative maximum telephone line length to achieve the North American recommended longitudinal ng level as a function of residual IT level, earth resistivity and separation distance .....	18
Table 6 – Measured 95 % values of THFF and $I_{pe}$ of a 600 MW scheme (3 phases).....	30
Table 7 – Measured 95 % values of THFF and $I_{pe}$ of a 300 MW scheme (3 phases).....	31
Table A.1 – Voltage distortion limits from IEEE 519 .....	44
Table A.2 – Compatibility levels for harmonic voltages (in percent of the nominal voltage) in LV and MV power systems .....	45
Table A.3 – Indicative values of planning levels for harmonic voltages in HV and EHV power systems.....	45
Table E.1 – Required total amount of installed filter Mvars to meet an IT limit of 25 kA for 600 MW transmission .....	63
Table F.1 – Some HVDC schemes – Specified telephone interference criteria .....	71

INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**High-voltage direct current (HVDC) systems -  
Guidance to the specification and design evaluation of AC filters -  
Part 2: Harmonic performance aspects**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62001-2 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment. It is a Technical Specification.

This first edition cancels and replaces IEC TR 62001-2 published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC TR 62001-2:2016:

- a) added Clause 3 on terms and definitions;
- b) split old Clause 3 to form new Clause 4 and Clause 5;
- c) extensive updating of text to reflect progress in time;
- d) transferred most of IEC TR 62001-3:2016, Annex C, to Clause 6.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
22F/863/DTS	22F/871/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

A list of all parts in the IEC 62001 series, published under the general title *High-voltage direct current (HVDC) systems – Guidance to the specification and design evaluation of AC filters*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

## INTRODUCTION

IEC 62001 (all parts) deals with the specification and design evaluation of AC side harmonic performance and AC side filters for HVDC schemes. It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing the specifications for new HVDC projects and evaluating designs proposed by prospective suppliers.

Harmonic performance is discussed in several places throughout the various parts of the IEC 62001 series and is also the topic of the IEC 61000 series.

The IEC 62001 series is structured in five parts as follows.

### IEC TR 62001-1 – Overview

This part concerns specifications of AC filters for high-voltage direct current (HVDC) systems with line-commutated converters, permissible distortion limits, harmonic generation, filter arrangements, filter performance calculation, filter switching and reactive power management and customer specified parameters and requirements.

### IEC TS 62001-2 – Harmonic performance aspects

This part deals with telephone interference, current-based interference criteria, field measurements and compliance verification.

### IEC TS 62001-3 – Modelling aspects

This part addresses modelling of three specific aspects of design: AC network impedance modelling, the treatment of pre-existing harmonics in performance and rating calculations, and harmonic interaction across converters (cross-modulation).

### IEC TR 62001-4 – Equipment

This part concerns steady-state and transient ratings of AC filters and their components, power losses, audible noise, design issues and special applications, filter protection, audible noise, seismic requirements, equipment design and test parameters.

### IEC TR 62001-5 – AC side harmonics and appropriate harmonic limits for high-voltage direct current (HVDC) systems with voltage sourced converters (VSC)

This part addresses the AC side harmonic performance of voltage sourced converters (VSC).

## **1 Scope**

This part of IEC 62001 gives a guidance to the specification and design evaluation of AC filters of high-voltage direct current (HVDC) systems, specifically on harmonic performance aspects. This document focusses on three specific areas of interest. Clause 4 discusses telephone interference related to the operation of HVDC transmission, including the derivation of appropriate harmonic limits. Clause 5 deals with all aspects of current-based harmonic performance criteria and their application. Clause 6 is concerned with field measurement and verification of compliance with specified harmonic limits.

This document concentrates on passive AC filter technology and line-commutated high-voltage direct current (HVDC) converters, but much of the content is equally relevant to VSC converter technology. Where there is a distinction, this is indicated in the text.

The scope of this document covers AC side filtering for the frequency range of interest in terms of harmonic distortion and audible frequency disturbances. It excludes filters specifically designed to be effective in the PLC and radio interference spectra.

## **2 Normative references**

There are no normative references in this document.

## Bibliography

- [1] CIGRE Technica Brochure 811, *DC side harmonics and filtering in HVDC transmission systems*, 2020
- [2] IEC TR 62001-1:2021, *High-voltage direct current (HVDC) systems - Guidance to the specification and design evaluation of AC filters - Part 1: Overview*
- [3] CIGRE WG14.03/CC.02 (JTF 02), *Connection of Harmonic Producing Installations in AC High-Voltage Networks with Particular Reference to HVDC. Guide for Limiting Interference Caused by Harmonic Currents with Special Attention for Telecommunication Systems*, Electra No. 159, April 1995
- [4] IEEE Std 368-1977, *IEEE Recommended Practice for Measurement of Electrical Noise and Harmonic Filter Performance of High-Voltage Direct-Current Systems*<sup>4</sup>
- [5] IEEE Std 519, *IEEE Standard for Harmonic Control in Electrical Power Systems*
- [6] CAN/CSA-C22.3 No. 3-98, *Electrical Coordination*, August 1998
- [7] A. Deri, G. Tevan, A. Semlyen and A. Castanheira, *The Complex Ground Return Plane: A Simplified Model for Homogeneous and Multi-Layer Earth Return*, IEEE Transactions on Power Apparatus and Systems, Vol. PAS-100, No. 8, August 1981, p. 3686-3693.
- [8] E.J. Rogers, J.F. White, IEEE Transaction on Power Delivery, *Mutual Coupling between Finite Lengths Parallel or Angled Horizontal Earth Return Conductors*, vol.4, no.1, Jan. 1989, p. 103-113
- [9] ITU, *Calculating induced voltages and currents in practical cases*, Directives concerning the protection of telecommunication lines against harmful effects from electric power and electrified railway lines, Volume II, 1999
- [10] IEEE Std 1124-2003, *IEEC Guide for Analysis and Definition of DC Side Harmonic Performance of HVDC Transmission Systems*
- [11] ITU-T K.68, *Operator responsibilities in the management of electromagnetic interference by power systems on telecommunication systems*
- [12] ITU-T EMC-1.6, *Danger, damage and disturbance*, Directives concerning the protection of telecommunication lines against harmful effects from electric power and electrified railway lines Volume VI, 2008
- [13] IEEE Std 820-2005, *IEEE Standard Telephone Loop Performance Characteristics*
- [14] *Electrical Coordination Guide*, Canadian Electrical Association, May 1989
- [15] IEEE Std 776-2018, *IEEE Recommended Practice for Inductive Coordination of Electric Supply and Communication Lines*
- [16] N.A. Patterson, D.E. Fletcher, IEEE Proceedings of the International Conference on DC Power Transmission, *The Equivalent Disturbing Current Method for DC Transmission Line Inductive Coordination Studies and DC Filter Performance Specification*, Montréal, Quebec, Canada, June 4-8, 1984, p. 198-204

---

<sup>4</sup> This document has been withdrawn.

- [17] M. Kuussaari, *Statistical Evaluation of Telephone Noise Interference Caused by AC Power Line Harmonic Currents*, IEEE Transaction on Power Delivery, Vol. 8, No. 2, April 1993
- [18] E.W. Kimbark, *Direct Current Transmission*, Volume 1, Wiley-Interscience, New-York, 1971
- [19] IEC TR 61000-3-6, *Electromagnetic compatibility (EMC) - Part 3-6: Limits - Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*
- [20] IEC TS 62001-3:2026, *High-voltage direct current (HVDC) systems - Guidance to the specification and design evaluation of AC filters - Part 3: Modelling aspects*
- [21] IEC TR 62544, *High-voltage direct current (HVDC) systems - Application of active filters*
- [22] CIGRE Technical Brochure, *Survey of Controls and Control Performance in HVDC Schemes*, Working Group 14-02, 1994
- [23] CIGRE WG 14.03, *AC Harmonic Filter and Reactive Compensation for HVDC, A General Survey*, Electra No. 63, p 65-102, 1979
- [24] CIGRE WG 14.03, *AC Harmonic Filter and Reactive Compensation for HVDC with Particular Reference to Non-Characteristic Harmonics*, Complement to the paper published in Electra No. 63(1979), CIGRE Technical Brochure No. 65, June 1990
- [25] IEC 61975, *High-voltage direct current (HVDC) installations - System tests*
- [26] IEC 61000-4-7, *Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*
- [27] IEC 61000-4-30, *Electromagnetic compatibility (EMC) - Part 4-30: Testing and measurement techniques - Power quality measurement methods*
- [28] IEC TR 61869-103, *Instrument transformers - The use of instrument transformers for power quality measurement*
- [29] J.Arrillaga and N. R Watson, *"Power System Harmonics"*, John Wiley and Sons, Ltd., 2003
- [30] CIGRE JTF 36.05.02/14.03.03, *"AC system modelling for AC filter design, An overview of impedance modelling"*, Electra No 164, p. 133 -151, June 1993
- [31] M. Tanaskovic, A. Nabi, S. Misur, P. Diamanti. R. McTaggart, *"Coupling Capacitor Voltage Transformers as Harmonics Distortion Monitoring Devices in Transmission Systems"*, IPST05, paper 031, 2005
- [32] F. Ghassemi, P.F. Gale, *"Method to Measure CVT Transfer Function"*, IEEE Transaction on Power Delivery, Vol. 17, No 4, October 2002
- [33] IEC TR 62001-4:2021, *High-voltage direct current (HVDC) systems - Guidance to the specification and design evaluation of AC filters - Part 4: Equipment*
- [34] IEC TS 61973, *High voltage direct current (HVDC) substation audible noise*

- [35] CCITT, *Danger And Disturbance*, Directives Volume VI, Geneva, 1989
  - [36] IEC TR 62001-5, *High-voltage direct current (HVDC) systems - Guidance to the specification and design evaluation of AC filters - Part 5: AC side harmonics and appropriate harmonic limits for HVDC systems with voltage sourced converters (VSC)*
  - [37] CIGRE WG B4.47, *Special aspects of AC filter design for HVDC systems*, CIGRE TB No. 553, 2013
  - [38] CIGRE WG 14.05, *Interaction between Converter and Nearby Generator*, CIGRE Brochure 119, October 1997
  - [39] IEC 62001 (all parts), *High-voltage direct current (HVDC) systems - Guidebook to the specification and design evaluation of AC filters*
  - [40] IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*
-