IEC TS 63222-1

Edition 2.0 2026-03

TECHNICAL SPECIFICATION

Power quality management -
Part 1: General guidelines

ICS 29.020

ISBN 978-2-8327-1125-5

IEC TS 63222-1:2026-03(en)

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 8
3 Terms, definitions and abbreviated terms 9
3.1 Terms and definitions 10
3.2 Abbreviated terms 12
4 Use cases list 13
4.1 List of business use case and business roles of the domains 13
4.2 List of system use cases and system roles 15
5 Provisions 16
5.1 Power quality assessment 16
5.1.1 General 16
5.1.2 Monitoring assessment 17
5.1.3 Monitoring assessment process 17
5.1.4 Predicted assessment 18
5.1.5 Predicted assessment process 18
5.1.6 Background description and analysis 18
5.1.7 Disturbance anticipation 18
5.1.8 Impacts analysis 19
5.2 PQ monitoring system 19
5.2.1 General 19
5.2.2 Monitoring points 19
5.2.3 Monitoring equipment 20
5.2.4 Related information and communication system 20
5.3 Economical assessment 21
5.3.1 General 21
5.3.2 Economical assessment of PQ provisions 21
5.3.3 Economical assessment of unsatisfactory PQ objectives/results 22
5.4 PQ requirement 23
5.5 Mitigation/troubleshooting 24
5.5.1 Total requirements 24
5.5.2 Power quality mitigation scheme 24
Annex A (normative) Use cases 26
A.1 Business use cases 26
A.1.1 BUC 1: Manage power quality over the grid 26
A.1.2 BUC 2: Connect new users to the grid 28
A.1.3 BUC 3: Plan network development 34
A.1.4 BUC 4: Manage complaints on power quality over the network 39
A.1.5 BUC 5: Provide reports on network power quality 46
A.1.6 BUC 6: Take into account power quality constraints in connecting a user to the grid 52
A.1.7 BUC 7: Take into account power quality constraints in network development 58
A.1.8 BUC 8: Take into account PQ constraints in network operation 63

A.1.9 BUC 9: Manage power quality through distribution or transmission grid interfaces with other networks 69
A.2 System UCs 72
A.2.1 SUC 1: Predict power quality impact of a construction work or maintenance 72
A.2.2 SUC 2: Predict power quality impact of a new connection or network development 79
A.2.3 SUC 3: Monitor power quality on the network 87
A.2.4 SUC 4: Measure power quality on a specific point of the network 94
A.2.5 SUC 5: Assess power quality on the network 100
A.2.6 SUC 6: Engineer a power quality solution 104
Annex B (informative) Main contents and requirements of power quality monitoring assessment report 110
B.1 Overview 110
B.2 Basic information of the assessment object 110
B.3 Basic information of power grid 110
B.4 Basis of assessment and standard 110
B.5 Monitoring instructions 110
B.6 Analysis and conclusion 110
B.7 Measures and suggestions (as required) 110
B.8 Attachments 110
Annex C (informative) Main contents and requirements of power quality predicted assessment report 111
C.1 Overview 111
C.2 Basic information of the assessment object 111
C.3 Basic situation of power grid 111
C.4 Basis of assessment and standard 111
C.5 Brief description of assessment method 111
C.6 Calculation and analysis 112
C.7 Measures and suggestions (as required) 112
C.8 Conclusion 112
C.9 Attachments 112
Annex D (informative) Economic data of power quality 113
D.1 Data structure 113
D.2 Basic data of economic cost of power users 113
D.3 Basic data of economic cost of public distribution network 114
D.4 Power quality related monitoring data 114
D.5 Equipment and system parameters 115
Bibliography 116

Figure 1 – Organisation of the use cases 13
Figure 2 – Overview of the power quality management main functions 17
Figure A.1 – Connect new users to the grid – Overview 31
Figure A.2 – Connect new users to the grid – Scenarios flow chart 32
Figure A.3 – Plan network development – Overview 36
Figure A.4 – Plan network development – Scenarios flow chart 37
Figure A.5 – Manage complaints on power quality over the network – Overview 42

Figure A.6 – Manage complaints on power quality over the network – Scenarios flow chart 43
Figure A.7 – Manage complaints on power quality over the network – Use case relationship 44
Figure A.8 – Provide reports on network power quality – Overview 49
Figure A.9 – Provide reports on network power quality – Scenarios flow chart 50
Figure A.10 – Take into account power quality constraints in connecting a user to the grid – Overview 55
Figure A.11 – Take into account power quality constraints in connecting a user to the grid – Overview 56
Figure A.12 – Take into account power quality constraints in network development – Overview 61
Figure A.13 – Take into account power quality constraints in network development – Scenarios flow chart 62
Figure A.14 – Take into account PQ constraints in network operation – Overview 66
Figure A.15 – Take into account PQ constraints in network operation – Flow chart 67
Figure A.16 – Manage power quality through distribution or transmission grid interfaces with other networks – Overview 71
Figure A.17 – Predict power quality impact of a construction work or maintenance – Overview 75
Figure A.18 – Predict power quality impact of a construction work or maintenance – Scenarios flow chart 76
Figure A.19 – Predict quality impact of a new connection or network development – Overview 83
Figure A.20 – Predict quality impact of a new connection or network development – Scenarios flow chart 84
Figure A.21 – Monitor power quality on the network – Overview 90
Figure A.22 – Monitor power quality on the network – Scenarios flow chart 91
Figure A.23 – Measure power quality on a specific point of the network – Overview 96
Figure A.24 – Measure power quality on a specific point of the network – Scenarios flow chart 97
Figure A.25 – Assess power quality on the network – Overview 103
Figure A.26 – Engineer a power quality solution – Overview 107
Figure A.27 – Engineer a power quality solution – Scenarios flow chart 107

Table 1 – Content of IEC TS 63222-1 7
Table 2 – Abbreviated terms of IEC TS 63222-1 12
Table 3 – Lists of business use cases 14
Table 4 – Business roles of IEC TS 63222-1 15
Table 5 – Lists of the system use cases 15
Table 6 – Lists of system roles 16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Power quality management - Part 1: General guidelines

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63222-1 has been prepared by IEC technical committee 8: System aspects of electrical energy supply. It is a Technical Specification.

This second edition cancels and replaces the first edition published in 2022. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) this document completes the use cases planned in IEC 63222-1:2022: four business use cases and three system use cases are added;
b) this document makes adjustments to the wording of certain phrases and technical details in IEC 63222-1:2022.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
8/1793/DTS	8/1803/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 63222 series, published under the general title *Power quality management*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,

– withdrawn, or

– revised.

INTRODUCTION

With the development of smart grid and massive deployment of renewable energy, power quality issues have received attention not only from system operators and customers (especially with sensitive power quality loads) but also from market regulators with the demands to provide information on the actual power quality level. Power quality management of the grid is a systematic project which includes the whole process of planning, operation, assessment and mitigation. The characteristics of power supplier, load characteristics of power consumer and external environment will affect the power quality of the grid. This document focuses on the whole process management and is the general guideline for the IEC 63222 series.

Traditional electrified railways, steel mills and other non-linear loads are the main pollution sources of the power quality. In recent years, the new loads such as new energy and electric vehicles have brought new challenges to power quality management. The rapid popularization and application of high-tech precision technology has also put forward new requirements for high-quality power supply and consumption system.

Power quality is an important issue for electricity supply network operators; it is also important to handle it at planning and operation stages. In order to achieve power quality target, reduce power quality impacts/losses and improve the economic efficiency of the system, power quality regulation and supervision of the operating power system is crucial, as well as a well-considered power quality planning before project implementation, such as system expansion, construction and grid connection of the distributed generation. Besides, the users at the end of power system should also be taken into consideration. Power quality problems can cause system instability, equipment abnormal operation and supply interruption. Power quality management is a method to avoid further power quality problems after project implementation.

The standard system in power quality management provides a technical basis for improving power management level and standardizing power quality industry and market. As the general guideline of the IEC 63222 series, this document summarizes the power quality indicators and assessment methods, and analyses the overall power quality level by monitoring assessment and predicted assessment. Monitoring system and field test are used to assess the power quality level at different nodes of the grid and solve users' power quality complaints and other practical problems. Connection and monitoring points are reasonably selected to assess the power quality levels of the grid in operation stage, and it also contributes to the power quality mitigation. In addition, the economical assessment of power quality is regulated in the document. Power quality management use cases in different typical scenarios are shown in Annex A.

1 Scope

This part of IEC 63222, which is a Technical Specification, is intended to provide provisions associated to the main use cases regarding recognized engineering practices applicable to power quality management in public electric power supply networks. It summarizes the operation in power quality management and investigates the current standards, for requirement of power quality assessment work, as well as to promote the development of power quality management best practices.

The power quality management domain groups use cases and associated power quality requirement common to network management, including customer support network operation, network and extension planning.

This document captures possible "common and repeated usage" of power quality management under the format of "use case". Use case implementations are given for information purpose only. This document derives the common requirement as provisions by further standardization activities, in terms of actors interacting with the given system. The interface requirement is considered for later standardization activities. The relationship of the stakeholders in power quality management, such as network operator, network user, etc, are discussed in the document. Table 1 highlights the domains and business use cases described.

Table 1 – Content of IEC TS 63222-1

Domain	Content	Scope
Power quality monitoring assessment	Described with 5 business use cases 1) Manage power quality over the grid. 2) Manage power quality through distribution or transmission grid interfaces with other network. 3) Take into account power quality constraints in network operation. 4) Provide reports on network power quality. 5) Manage complaints on power quality over the network. 6) Manage power quality through distribution or transmission grid interfaces with other network. Described with 4 system use cases 1) Measure power quality on a specific point of the network. 2) Monitor power quality on the network. 3) Engineer a power quality solution. 4) Assess power quality on the network.	Continuous monitoring operation for public power grid

Domain	Content	Scope
Power quality predicted assessment	Described with 7 business use cases 1) Manage power quality over the grid. 2) Connect new user to the grid. 3) Plan network development. 4) Take into account power quality constraints in connecting a user to the grid. 5) Take into account power quality constraints in network development. 6) Provide reports on network power quality. Described with 6 system use cases 1) Predict power quality impact of a construction work or maintenance. 2) Predict power quality impact of a new connection or network development. 3) Measure power quality on a specific point of the network. 4) Monitor power quality on the network. 5) Engineer a power quality solution. 6) Assess power quality on the network	Power quality assessment of new construction, reconstruction or expansion projects in the grid

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-3 (all parts), *Electromagnetic compatibility (EMC) - Part 3: Limits*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply system, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*

IEC TS 61000-3-4, *Electromagnetic compatibility (EMC) - Part 3-4: Limits - Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A*

IEC TS 61000-3-5, *Electromagnetic compatibility (EMC) - Part 3-5: Limits - Limitation of voltage fluctuations and flicker in low-voltage power supply systems for equipment with rated current greater than 75 A*

IEC TR 61000-3-6, *Electromagnetic compatibility (EMC) - Part 3-6: Limits - Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*

IEC TR 61000-3-7, *Electromagnetic compatibility (EMC) - Part 3-7: Limits - Assessment of emission limits for the connection of fluctuating load installations to MV, HV and EHV power systems*

IEC 61000-3-8, *Electromagnetic compatibility (EMC) - Part 3: Limits - Section 8: Signalling on low-voltage electrical installations - Emission levels, frequency bands and electromagnetic disturbance levels*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) - Part 3-11: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) - Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current >16 A and ≤ 75 A per phase*

IEC TR 61000-3-13, *Electromagnetic compatibility (EMC) - Part 3-13: Limits - Assessment of emission limits for the connection of unbalanced installations to MV, HV and EHV power systems*

IEC TR 61000-3-14, *Electromagnetic compatibility (EMC) - Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems*

IEC 61000-4 (all parts), *Electromagnetic compatibility (EMC) - Part 4: Testing and measurement techniques*

IEC 61000-4-15, *Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications*

IEC 61000-4-30:2015, *Electromagnetic compatibility (EMC) - Part 4-30: Testing and measurement techniques - Power quality measurement methods*

IEC TR 61850-90-17:2017, *Communication networks and systems for power utility automation - Part 90-17: Using IEC 61850 to transmit power quality data*

IEC 61968-9:2024, *Enterprise business function interfaces for utility operations - Part 9: Interfaces for meter reading and control*

IEC TS 62749:2020, *Assessment of power quality - Characteristics of electricity supplied by public networks*

IEC TS 63222-2:2023, *Power quality management - Part 2: Power quality monitoring system*

ISO 10002:2018, *Quality management - Customer satisfaction - Guidelines for complaints handling in organizations*

Bibliography

IEC references

IEC 60038:2009, *IEC standard voltages*
IEC 60038:2009/AMD1:2021

IEC 60050-161, *International Electrotechnical Vocabulary - Part 161: Electromagnetic compatibility,* available at <http://www.electropedia.org/

IEC 60050-551, *International Electrotechnical Vocabulary (IEV) - Part 551: Power electronics,* available at <http://www.electropedia.org/

IEC 60050-617, *International Electrotechnical Vocabulary (IEV) - Part 617: Organization/Market of electricity,* available at <http://www.electropedia.org/

IEC 60050-714, *International Electrotechnical Vocabulary (IEV) - Part 714: Switching and signalling in telecommunications,* available at <http://www.electropedia.org/

IEC 60050-721, *International Electrotechnical Vocabulary (IEV) - Part 721: Telegraphy, facsimile and data communication,* available at <http://www.electropedia.org/

IEC 60050-732, *International Electrotechnical Vocabulary (IEV) - Part 732: Computer network technology,* available at <http://www.electropedia.org/

IEC 60050-901, *International Electrotechnical Vocabulary (IEV) - Part 901: Standardization,* available at <http://www.electropedia.org/

IEC 60050-904, *International Electrotechnical Vocabulary (IEV) - Part 904: Environmental standardization for electrical and electronic products and systems,* available at <http://www.electropedia.org/

IEC 61000-4 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61850 (all parts), *Communication networks and systems for power utility automation*

IEC 63222 (all parts), *Power quality management*

Non-IEC references

CIGRE/CIRED JWG C4.112:2014, *Guidelines for Power Quality Monitoring - Measurement locations, processing and presentation of data*

J. M. R. GORDON, C. NOCE, *Enel global solution for power quality monitoring and analysis.* CIRED, Volume 2017, issue 1, no. 645.

_____