IEC TS 63346-2-1

Edition 1.0 2026-06

TECHNICAL SPECIFICATION

Low-voltage auxiliary power systems -
Part 2-1: Design criteria - General requirements

ICS 29.240

ISBN 978-2-8327-1303-7

IEC TS 63346-2-1:2026-06(en)

CONTENTS

FOREWORD 2
1 Scope 4
2 Normative references 4
3 Terms and definitions 5
4 Basic requirements 5
4.1 Design principles 5
4.1.1 Safety 5
4.1.2 Reliability 6
4.1.3 Future modification and expansion 6
4.2 Determination of operational conditions and external influences for design 6
4.2.1 Operational conditions 6
4.2.2 External influences 6
4.3 System configuration 6
4.3.1 General 6
4.3.2 AC systems 7
4.3.3 DC systems 8
5 Safety and protection requirements 9
5.1 General 9
5.2 Transient and temporary overvoltage 9
5.3 Protection against voltage disturbances and electromagnetic disturbances 10
5.4 Thermal effects 10
5.5 Internal arc faults 10
5.6 Protection against explosion 11
6 System design 11
6.1 AC system 11
6.1.1 Voltage classes 11
6.1.2 Types of system earthing 11
6.1.3 Protection against overcurrent 11
6.1.4 System schemes 11
6.1.5 Loads 12
6.2 DC system 12
6.2.1 Voltage classes 12
6.2.2 Types of system earthing 12
6.2.3 Protection against overcurrent 13
6.2.4 System schemes 13
6.2.5 Loads 14
7 SCADA, measurement and online monitoring 14
7.1 Measurement and SCADA 14
7.2 Online monitoring 14
Bibliography 15

Figure 1 – High-level block diagram of typical AC system configurations 11
Figure 2 – High-level block diagram of typical DC system configurations 13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Low-voltage auxiliary power systems - Part 2-1: Design criteria - General requirements

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63346-2-1 has been prepared by IEC project committee 127: Low-voltage auxiliary power systems for electric power stations and substations. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
127/87/DTS	127/88/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 63346 series, published under the general title *Low-voltage auxiliary power systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,

– withdrawn, or

– revised.

1 Scope

This part of IEC 63346 establishes the general principles for the design of low-voltage auxiliary power systems (APS) with nominal voltages below or equal to 1 kV AC and 1,5 kV DC, and nominal frequency up to and including 60 Hz, so as to provide safe and correct operation for the intended use.

This document applies to the design of low-voltage auxiliary systems for

– substations, which are part of an electrical system, confined to a given area, mainly including ends of transmission or distribution lines, electrical switchgear and controlgear, buildings and transformers,
– converter stations,
– hydropower stations, where the gravitational energy of water is converted into electricity, and
– thermal power stations, where the thermal energy is obtained by burning fossil fuels.

This document does not apply to the design of low-voltage auxiliary power systems of the following:

– nuclear power stations, which have extremely high safety requirements and special loads, such as nuclear measurement systems and protection systems;
– substations connecting a nuclear power station to the grid and its associated LV APS integrated with the nuclear power station;
– traction substation, which have different power supply requirements, such as unbalanced load power supply;
– offshore substations, for which it is important to take into account factors such as waves, typhoons and salt spray, which have different requirements for power supply and equipment selection.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60079-0, *Explosive atmospheres - Part 0: Equipment - General requirements*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-1:2025, *Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics and definitions*

IEC 60364-4-42*, Low-voltage electrical installations - Part 4-42: Protection for safety - Protection against thermal effects*

IEC 60364-4-43*, Low-voltage electrical installations - Part 4-43: Protection for safety - Protection against overcurrent*

IEC 60364-4-44*, Low-voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-51:2005*, Electrical installations of buildings - Part 5-51: Selection and erection of electrical equipment - Common rules*

IEC 60364-5-52, *Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems*

IEC 60364-5-53, *Low-voltage electrical installations - Part 5-53: Selection and erection of electrical equipment - Devices for protection for safety, isolation, switching, control and monitoring*

IEC 60909-0*, Short-circuit currents in three-phase a.c. systems - Part 0: Calculation of currents*

IEC 60947-1, *Low-voltage switchgear and controlgear - Part 1: General rules*

IEC 60947-2, *Low-voltage switchgear and controlgear - Part 2: Circuit-breakers*

IEC 61439-1, *Low-voltage switchgear and controlgear assemblies - Part 1: General rules*

IEC 61439-2, *Low-voltage switchgear and controlgear assemblies - Part 2: Power switchgear and controlgear assemblies*

IEC TR 61641, *Enclosed low-voltage switchgear and controlgear assemblies - Guide for testing under conditions of arcing due to internal fault*

IEC 61643-12, *Low-voltage surge protective devices - Part 12: Surge protective devices connected to low-voltage power systems - Selection and application principles*

IEC 61660-1, *Short-circuit currents in d.c. auxiliary installations in power plants and substations - Part 1: Calculation of short-circuit currents*

IEC 61936-1, *Power installations exceeding 1 kV AC and 1,5 kV DC - Part 1: AC*

IEC TS 63346-1-1, *Low-voltage auxiliary power systems - Part 1-1: Terminology*

Bibliography

IEC 60076 (all parts), *Power transformers*

IEC 60664-1, *Insulation coordination for equipment within low-voltage supply systems - Part 1: Principles, requirements and tests*

IEC 60947-9-2, *Low-voltage switchgear and controlgear - Part 9-2: Active arc-fault mitigation systems - Optical-based internal arc-detection and mitigation devices*

IEC TR 61912-1, *Low-voltage switchgear and controlgear - Overcurrent protective devices - Part 1: Application of short-circuit ratings*

IEC TR 61912-2, *Low-voltage switchgear and controlgear - Over-current protective devices - Part 2: Selectivity under over-current conditions*

_____